


TYPICAL UTILITY DUCT DETAIL AT PIER E2 AND PANEL POINT 126



TYPICAL UTILITY CABLE PENETRATION DETAIL

REQUESTS FOR INFORMATION NOT ADDRESSED IN THIS CCO REMAIN IN FORCE							
05/06/08 BARRIER MODIFICATIONS					DT	AS	44
MARK	DATE		DESCRI	PTIONS	BY	CH, D	CCO.
	REVISIONS						
CONTRACT CHANGE ORDER NO.							

SHEET ____ OF ___

Valizadeh/V. Toan/Y.L./W.L./F.C.




G. Baker


S. Camo

C. Mauch


DETAILS



TYPICAL UTILITY CONDUIT AND TOWER DISCHARGE PIPE PENETRATION DETAIL



SECTION B-B (see Note 5)



T. Ho

D. Harrison

STATE OF CALIFORNIA

DEPARTMENT OF TRANSPORTATION



tric		4 0 (
	04	SF	80	13.2/13.9	965R I	1204
	0151	COUNTY	ROUTE	TOTAL PROJECT	NO.	SHEETS

George S. Bak

C57112

Exp. 12/31/05

CIVII

PLANS APPROVAL DATE The State of California or its officers or ag shall not be responsible for the accuracy of

.Y. LIN / MOFFATT & NICHOL 825 BATTERY STREET SAN FRANCISCO, CA 94111

To get to the web site, go to: http://www.dot.ca.gov

PIPE SLEEVE TABLE

Conduit Nominal size	Pipe sleeve Nominal size	Minimum Spacing (See Note 8)						
27	51	150						
4 I	64	200						
53	76	250						
63	89	300						
78	102	500						
91	127	1000						
103	127	1000						

NOTES:

I. TS 305x152 at Pier E2 shall extend through all three webs of floorbeam E2.

 \mathbb{C}^2 . All pipe sleeves shall be A53 GR B or an equivalent steel grade as approved by the Engineer and shall be detailed to accommodate actual utility conduit and pipe sizes. For utility conduit, pipe and cable sizes, see "Road Plans". For tower discharge pipe, see "Tower Drainage Details No.!" sheet.

- For pipe sleeves sizes, see "Pipe Sleeve Table". Contractor shall be responsible for fit-up, support and sealing of pipes and conduits in the pipe sleeves. Contractor may select alternative pipe sleeve sizes to suit the actual conduits and pipes
- 4. For conduit mounting details, see "Road Plans".
- 5. For mounting and sealing cables in pipe sleeves, see "Road Plans".
- 6. For conduit penetrations at panel point 41, see "Girder Transition Near Tower" sheets.
- 7. For conduit penetrations at utility platforms, see Typical Crossbeams Details" sheets.
- 8. Unless otherwise noted or approved by the Enginner pipe sleeves may not be located in the unreinfoced girder skin plates at less than the minimum spacing.
- 9. IO mm plate welded to pipe sleeve to vary in width depending on O.D. of pipe.
- 10. Dimension and size of holes in plate depend on
- (II. Edge of plate to align with inside edge of pipe

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN

Manzanarez

PROJECT ENGINEER

SAN FRANCISCO OAKLAND BAY BRIDGE EAST SPAN SEISMIC SAFETY PROJECT SELF-ANCHORED SUSPENSION BRIDGE (SUPERSTRUCTURE & TOWER)

UTILITY DETAILS NO. I

DISREGARD PRINTS BEARING EARLIER REVISION DATES -548R I

08/02/99 05/31/01 04/08/02 07/01/02 12/19/02 ILE => 1:\bb\04-012001\sas\contract plans and cco\cco\in progress\cco#44\revised 8-25-08\dgn\akmscl3.dgr

BRIDGE NO.

34-0006L/

KILOMETER POS

13.2/13.





